



NOTES

- 1 MINIMUM CONDUIT TRADE SIZE IS 1 INCH
- 2 FOR FIRE ALARM RISER DIAGRAM, REFER TO SHEET E-19
- 3 (O) DEVICES AND CONDUIT SHOWN LIGHTLY, NEW DEVICES AND CONDUIT SHOWN HEAVILY

THIRD FLOOR AND PARTIAL ROOF FIRE ALARM PLAN 1/8"=1'

GEZ
ARCHITECTS
ENGINEERS

4	CC	ASH	10/20/00	RECORD DRAWING
3	CC	ASH	2/1/00	ISSUED FOR CONSTRUCTION (REVISED)
2	INJ	ASH	1/3/00	ISSUED FOR CONSTRUCTION
1	INJ	ASH	10/16/99	FIRE ALARM PACKAGE

BLDG. 70
HAZARDOUS MATERIALS SAFEGUARDS
THIRD FLOOR & PARTIAL ROOF
FIRE ALARM PLAN
UNIVERSITY OF CALIFORNIA LAWRENCE BERKELEY LABORATORY
FACILITIES DEPARTMENT

DESIGNED BY	INJ	DATE	10/12/00
APPROVED BY	ASH	DATE	10/20/00
SCALE	1/8"=1'	PROJECT NO.	4B70E118A
SHEET NO.	2808	REVISION	E-18